

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7161-1509:100 Page 1 of 1

CATEGORY: Cables-Fire Protective Signaling

LISTEE: *Lake Cable, LLC, 2020 N. Austin Ave., Chicago, IL 60639
Contact: Noubar Sarkissian (773) 385-8700 Fax (773) 385-8770

DESIGN: Types FPL, FPLP and FPLR power limited fire protective signaling cables.

Insulation – PVC compound AlphaGary Smokeguard 4010, Synergistics 1349-1028 FRD, 1360-1021-PID, PP, HDPE or LDPE.

Shields - (Optional) All metal or Aluminum Polyester tape.

Braid – (Optional) All metal.

Jacket - PVC compound AlphaGary Smokeguard II 6920, Gitto Global GA-8705-03, AlphaGary GW2038, Synergistics 1690-1060, 1604-1007 FR, 1100-1092 FRD, JAP61A or 1410-1011 FRD, Solef 31008-0003.

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NEC Article 760, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, Type FPL, FPLP or FPLR, rating and UL label.

APPROVAL: Listed as power-limited fire protective signaling cables.

*Revised 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager